



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**PERMIT TO OPERATE**

T010089

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: DECEMBER 2026**

**OWNER OF OPERATOR (Co.#1780)**

Love's Travel Stop #374  
P.O. Box 26210  
Oklahoma City, OK 73126

**EQUIPMENT LOCATION (Fac.#3021)**

Love's Travel Stop #374  
2974 Lenwood Road  
Barstow, CA 92311

**Description:**

DIESEL AND BIODIESEL BLENDING & RETAIL DISPENSING FACILITY consisting of: Eight (8) 12,000 gallon capacity Aboveground Storage Tanks (USTs) used for storage and dispensing of Diesel and Biodiesel fuel. See permit G010088 for gasoline dispensing.

**EQUIPMENT**

Capacity	Equipment Description
12000	Diesel Storage Tank 1 AST
12000	Diesel Storage Tank 2 AST
12000	Diesel Storage Tank 3 AST
12000	Diesel Storage Tank 4 AST
12000	Diesel Storage Tank 5 AST
12000	Diesel Storage Tank 6 AST
12000	Biodiesel Storage Tank 7 AST
12000	Biodiesel Storage Tank 8 AST

**CONDITIONS:**

Fee Schedule: 5 (b)

Rating: 96000 gallons

SIC: 5541

SCC: 40600651

Location/UTM(Km):  
498E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Love's Travel Stop #374  
P.O. Box 26210  
Oklahoma City, OK 73126

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.  
[District Rule 1302]
  
2. These tanks shall only be used to store Ultra Low Sulfur Diesel (ULSD) and Biodiesel Fuels.  
[District Rules 463 and 1320]
  
3. All of the components of these tanks, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations.  
[District Rule 463(C)(3)]
  
4. The owner/operator shall maintain a log of all inspections, repairs, and maintenance on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.  
[District Rule 463]
  
5. The owner/operator shall keep a monthly summary of the throughput for the calendar year to date. This log shall be kept on site and available to District personnel upon request.  
[District Rule 462]
  
6. The annual throughput of gasoline shall not exceed 50,000,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.  
[District Rule 1320]