



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**PERMIT TO OPERATE**

T011434

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: AUGUST 2026**

**OWNER OF OPERATOR (Co.#15)**

Pacific Gas & Electric/Air Permits  
PO Box 28150  
Oakland, CA 94604-8150

**EQUIPMENT LOCATION (Fac.#39)**

PG&E - Topock Compressor Station  
145453 National Trails Highway  
Needles, CA 92363

**Description:**

NATURAL GAS ODORANT STORAGE & INJECTION SYSTEM consisting of: Transwestern odorant injection system with 5000 gallon above ground odorant tank and related equipment.

**CONDITIONS:**

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be properly maintained and kept in good operating condition at all times
3. This tank shall not be filled to greater than 90% of its maximum capacity (to allow for expansion within tank.)
4. The odorant tank and the delivery truck used to fill the odorant tank must be equipped with a Two Point Phase I type vapor recovery system.
5. A Two Point Phase I type vapor recovery system must be utilized whenever the odorant tank is being filled.
6. A closed loop system shall be used to ensure that odorant discharged to the atmosphere is minimized during equipment maintenance.

Fee Schedule: 5 (a)

Rating: 5000 gallons

SIC: 4922

SCC: 9999999

Location/UTM(Km):  
730E/3844N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits  
PO Box 28150  
Oakland, CA 94604-8150

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer