

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

T011720

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: FEBRUARY 2014

OWNER OF OPERATOR (Co.#15)

Pacific Gas & Electric/Air Permits PO Box 28150 Oakland,CA94604-8150

EQUIPMENT LOCATION (Fac.#3419)

PG&E - Essex Odorization Station - PLS1A Six Miles S. of Esses on Sunflower - PLS1A Essex,CA92332

Description:

ODORANT TANK AND INJECTION SYSTEM consisting of:Odorant injection system with 2000 gallon above ground odorant tank and related equipment

CONDITIONS:

- 1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
- 2. This equipment shall be properly maintained and kept in good operating condition at all times.
- 3. This tank shall not be filled to greater than 90% of its maximum capacity (to allow for expansion within tank).
- 4. The odorant tank and the delivery truck used to fill the odorant tank must be equipped with a Two Point Phase I type vapor recovery system.
- 5.A Two Point Phase I type vapor recovery system must be utilized whenever the odorant tank is being filled.
- 6.Flame destruction shall be used to ensure that the odorant shall not be discharged to the atmosphere during equipment maintenance.

Fee Schedule:5 (a)

Rating:2000gallons

SIC:4922

SCC:10300603

Location/UTM(Km):660E/3845N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits PO Box 28150 Oakland, CA94604-8150

By: COPY
Brad Poiriez
Air Pollution Control Officer