



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T014068

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JUNE 2027

OWNER OF OPERATOR (Co. #1994)

Southwest Gas Company
8360 South Durango Drive
Las Vegas, CA 89113

EQUIPMENT LOCATION (Fac. #4062)

South West Gas - VVWRA RNG
20111 Shay Road
Victorville, CA 92394

Description:

ODORANT TANK AND INJECTION SYSTEM consisting of: Odorant injection system with 60 gallon above ground odorant tank and related equipment

CONDITIONS:

1. This equipment shall be installed, operated and maintained in good operating condition and in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 402]

2. The odorant tank and the delivery truck used to fill the odorant tank must be equipped with a Two Point Phase I type vapor recovery system capable of achieving 95% control; this vapor recovery system must be utilized whenever the odorant tank is being filled.

[District Rules 402 and 1303]

3. This tank shall not be filled to greater than 90% of its maximum capacity (to allow for expansion within tank).

[District Rule 402]

Fee Schedule: 5 (a)

Rating: 60 gallons

SIC: 4924

SCC: 30600811

Location/UTM(Km):
467E/3831N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southwest Gas Company
8360 South Durango Drive
Las Vegas, NV 89113

By: **COPY**
Brad Poiriez
Executive Director

4. A closed loop system shall be used and maintained to ensure that odorant discharged to the atmosphere is minimized during equipment servicing and maintenance.

[District Rule 402]

5. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]