



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**AUTHORITY TO CONSTRUCT**

T014976

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

**EXPIRES LAST DAY OF: FEBRUARY 2027**

**OWNER OF OPERATOR (Co.#460)**

Sully-Miller Contracting, Co  
135 State College Blvd Suite 400  
Brea, CA 92821

**EQUIPMENT LOCATION (Fac.#2933)**

Sully-Miller Contracting Co- Air Expressway  
15650 Air Expressway  
Victorville, CA 92392

**Description:**

REACTION TANK, 30,000 GALLON consisting of: Reaction Tank, Two Compartments, 30,000 Gallons total with Two Augers, 20 HP total, an offloading pump, 20 HP, and a D&H Equipment Vent Condenser. This tank is part of a Crumb Rubber Blending System permitted under valid District Permit B014975.

**CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 204]
2. This equipment shall only be used for storage of rubberized hot asphalt oil mix. [District Rule 1320]
3. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations. [District Rule 463(C)(3)]

Fee Schedule: 5 (b)

Rating: 30000 gallons

SIC: 2951

SCC: 4068801

Location/UTM(Km):  
470E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Sully-Miller Contracting, Co  
135 State College Blvd, Suite 400  
Brea, CA 92821

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

4. This reaction tank shall be restricted to a material throughput of 16,000,000 gallons per year.  
[District Rule 1303]

5. This equipment shall not be operated unless vented through a properly operating integral Blue Smoke Condenser.  
[District Rules 401, 402, and 1302]

6. This equipment and associated operations shall not discharge an exhaust stream that exhibits opacity greater than twenty percent (Ringlemann 1).  
[District Rule 401]

7. The owner/operator shall maintain an operations log for this equipment, current and on-site (or at a central location) for a minimum of two (2) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

- a. Record of liquids stored in this tank, verified by MSDS and by retention of the waste manifests issued upon disposal of waste oil.
- b. A log containing any repairs and maintenance conducted on this equipment.

[District Rule 463 (D)(1) and (D)(3)]

8. A facility wide Comprehensive Emission Inventory Report (CEIR) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, annually.

[District Rule 107(b), Health & Safety Code 39607 & 44341-44342, 17 CCR 93400 et seq., and 40 CFR 51, Subpart A]